



MP URJA VIKAS NIGAM LTD.,
URJA BHAVAN, MAIN ROAD # 2, NEAR BUS-STOP # 5, BHOPAL – 462016
PHONE # 0755-2553595, 2556566, FAX # 0755 – 2553122, E-Mail: cmpuvn@bsnl.in
Website: www.mprenewable.nic.in

RFP No .MPUVN/RFP-Notice/SPVPP/Pre bid/ 0.5-4kWp & 5- 25kWp /2011-12/

Bhopal Dated 16/05/2011

Sub:-MINUTES OF PRE-BID MEETING HELD ON 12-05-2011 AT 12-30 PM IN THE CONFERENCE HALL OF MP URJA VIKAS NIGAM LTD. BHOPAL.

Ref: -RFP No .MPUVN/RFP-Notice/SPVPP 0.5-4kWp & 5- 25kWp /2011-12/300 Dated 28/04/2011

In furtherance to the issuance of the RFP mentioned above, the prebid meeting as scheduled took place in presence of the aspiring participants. The minutes of the meeting are as hereunder:-

(1) Eligibility Criteria (Document A & B):

- 1.1) Eligibility Criteria was explained to all the aspiring Participants in details, (given at page – 4 & 5 of RFP document). It was clarified that the mandatory conditions as explained in the RFP document are to be fulfilled in respect of Technical and Financial aspects..
- 1.2) For the purpose of having maximum participation, and facilitation for meeting the required Financial / Commercial parameters such as Net worth and Turn over ,the aspiring Participants are allowed to form Joint Venture, Consortium . It is further clarified that
 - (i) Original copy of Agreement (on Rs.100.00 Non-judicial Stamp paper) should be necessarily enclosed in support of the formation of Joint Venture /Consortium.
 - (ii) Technical eligibility parameters such as aggregate capacity installed, minimum experience of single system shall be considered only of the leading partner of the Joint Venture or Consortium.
- (3) It was informed to the participants to carefully go through the page 10-11 of RFP (Document A & B) documents wherein directives for preparation and submission of proposals are elaborated. The participants were requested to follow the instructions explained at this page and accordingly submit their proposals in four different envelopes all placed in single envelope.
- (4) Participants were explained about the scope of work and specifications in detail of Document A & B. Some of the specific clarifications are given below:
 - (4.1) System Design Configurations given on page No. 29 to 36 & 45 were explained in detail. It was informed by some of the participants that system operating voltages for capacities of 15KW and above, may be allowed to be increased as per availability of the Power conditioning units/Inverters. Keeping in view that this would further reduce operational losses and shall not affect efficiency of the system, the participants are allowed to incorporate PCU/Inverter of higher operating voltages than that mentioned in the RFP Document for the capacities of 15 KW and above only.

- (4.2) Minimum technical requirement in terms of SPV array, battery bank, power conditioning unit, and other system accessories shall remain same except for the provision of MJB for capacities of 500W and 1000W systems where it is not found to be essential.
- (5) It was announced loud & clear that no deviations shall be allowed in terms & conditions of payments.
- (6) Meeting ended with vote of thanks to participants & representatives.

List of Participant who attended the pre-bid meeting :

S.No.	Name of participants	Name of the Organisation
1.	Shri Umesh Shetty	M/s. Megatech Power System Pvt. Ltd. Pune
2.	Representative	M/S Ayushi Akshaya Urja, Laltipur
3.	Shri Anand Patel	M/S EL-Sol Energy Systems, Ahmedabad
4.	Shri Shishir Saini	M/s. Su-Kam Power Systems Ltd., Gurgaon
5.	Shri Lalit Kumar	M/s. Creative Infrapower Ltd., New Delhi
6.	Shri G.S. Chopra	M/s. Emmvee Photo Voltaic Pvt. Ltd.
7.	Shri Anil Sahoo	M/s. HBL Power System Ltd.,Gurgaon
8.	Shri Ashish Pandey	M/s. Micromax Energy Ltd., New Delhi
9.	Shri Khurshid Ansari	M/s. Nuetech Solar Systems Pvt Ltd., Bhopal
10.	Shri Nitin R. Kulkarni	M/s. Jain Irrigation Systems Ltd., Indore
11.	Shri Vivek Jain	M/s. Jain Irrigation Systems Ltd.,
12.	Shri R. P. Patel	M/s. BRIO Energy, Mumbai
13.	Shri Anjan Shukla	M/s Agni Power & Electronics Pvt. Ltd., Kolkata
14.	Shri Anil Singh	M/s. Solid Solar Gautam Polymers Group
15.	Shri Hemant Sarathe	M/s. Indian Power Controlling Systems, Bhopal
16.	Shri Anand Jain	M/s. Technical Systems, Bhopal
17.	Shri Deepesh Verma	M/s. Amara Raja Batteries Ltd., Indore
18.	Shri Ashutosh Mishra	M/s. Perfect Power Systems
19.	Shri Adityanarayan Yadav	M/s. Entegra Ltd., Bhopal
20.	Shri Sunil Shukla	M/s. Titan Energy Systems Ltd., Secunderabad
21.	K. Vedavathi	M/s. Rugveda Renewable Energies
22.	Shri Nikhil Dash	M/s. Mahindra & Mahindra Ltd., Mumbai
23.	Shri K.N. Rao	M/s. Vennser Telecom Pvt. Ltd. , Hyderabad

Important Note:- PARTICIPANTS ARE REQUESTED TO SUBMIT A COPY OF MINUTS OF PRE-BID MEETING DULLY SIGNED AND WITH COMPANY SEAL AFFIXED WITH THEIR PROPOSAL IN ENVELOPE NO -1 (Envelope for "Minimum Eligibility Criteria")

-sd-

(Shrikant Deshmukh)
For and on behalf of
MPUVN