




CORRIGENDUM-II

In context with RFP No.MPUVN/SWH/2020/450 dated 26-06-2020.

1. For different capacity of solar water heating systems the following diameter of hot water pipe line (CPVC pipe line with insulation as per RFP specification) will be consider.
 - a. Solar water heating systems capacity of 500 LPD - 1 inch hot water piping
 - b. Solar water heating systems capacity of 1000 LPD - 1 inch hot water piping
 - c. Solar water heating systems capacity of 2500 LPD - 1.5 inch hot water piping
2. For categories A1, A2, A3 in the financial report section-VI schedule-B cost component-IV and V the blended rate for corresponding unit size and corresponding diameter of hot water pipe shall be quoted.
3. In Annexure-18 serial no. 1 in the table, Column-IV "rate quote" shall be left blank the bidder shall quote the % discount only as per Column-V.
4. Section -VI, schedule-B there should be no ceiling of SOR rates. Point no. 4 "Bid quoted with rates higher that SOR in schedule be shall be rejected" is deleted from RFP.

All the changes mentioned above would be part of the updated RFP.


(Superintending Engineer)